



Tel : 0674-2564033/  
EPABX : 2561909/2562847  
E-mail: paribesh1@ospcboard.org  
Website: [www.ospcboard.org](http://www.ospcboard.org)

## STATE POLLUTION CONTROL BOARD, ODISHA

[DEPARTMENT OF FOREST & ENVIRONMENT, GOVERNMENT OF ODISHA]


Paribesh Bhawan, A/118, Nilakanthanagar, Unit-VIII,  
Bhubaneswar 751012

No. 11340 / IND-I-CON - (Misc)56 (vol-III)

Dt 06.08.2021

### OFFICE ORDER

In continuation to the Gazette Notification published by Ministry of Environment, Forest and Climate Change, New Delhi on 19.10.2020 the standard for Oxides of Nitrogen (NO<sub>x</sub>) for Thermal Power Plants installed after 1<sup>st</sup> Jan, 2003 up to 31.12.2016 has been amended from 300mg/Nm<sup>3</sup> to 450mg/Nm<sup>3</sup>. Therefore, the standard for NO<sub>x</sub> in the existing consent to operate order of Thermal Power Plants installed during the above said period may be read as 450mg/Nm<sup>3</sup>. Further, the standards for PM and SO<sub>2</sub> remain unchanged in all respect.

  
Member Secretary


Memo No. 11341 /dtd. 06.08.2021

Copy forwarded to All Thermal Power Plants operating in the state of Odisha for information and necessary compliance.

  
Chief Env. Engineer

✓ Memo No. 11342 /dtd. 06.08.2021

Copy forwarded to EE-cum-System Administrator, SPC Board, Bhubaneswar for information. She is requested to upload the officer order in Board's website for wide circulation.

  
Chief Env. Engineer