

Status of Sewage Treatment Plants in Uttarakhand (July-September, 2022)

- Commissioned STPs - 53 (18 towns) with designed capacity – 341.2 MLD
- Operational STPs – 51* (Operational capacity - 341.1 MLD) with Utilized capacity – 228.6 MLD (~67% of operational capacity)
- Compliance Status of operational STPs

	Compliance w.r.t. Hon'ble NGT vide order 30.04.2019	Compliance Status w.r.t MoEF norms dated 13.10.2017
Complying	6	8
Non-complying	45	43

- Non-operational STPs – 2 (Designed capacity – 0.1 MLD)
- STPs complying for Faecal Coliform norms (<230 MPN/100ml) – 7
- STPs non-complying for Faecal Coliform norms (>230 MPN/100ml) – 44

Operational and Compliance status of Sewage Treatment Plants in Uttarakhand

S. No.	Name of STPs/CETPs	Ganga Front Town	Treatment Technology	Designed Capacity (MLD)	Date of Inspection	Operational /Non-Operational Status	Compliance Status w.r.t Hon'ble NGT norms dated 30.04.2019	Compliance Status w.r.t MoEF&CC norms dated 13.10.2017
1	Gangotri	Gangotri	SBR	1	04.06.2022	Operational	Non-complying COD, BOD	Complying
2	Badrinath 1.0 MLD STP*	Badrinath	SBR	1	08.06.2022	Operational	Non-complying FC	Non-complying FC
3	Badrinath 0.01MLD STP	Badrinath	MBBR	0.01	08.06.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying TSS, BOD, FC
4	Badrinath 0.26 MLD STP	Badrinath	SBR	0.26	08.06.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying TSS, BOD, FC
5	Old Suspension bridge	Chamoli-Gopeshwar	Electro-coagulation	0.05	24.05.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying BOD, FC
6	Chamoli Ghat	Chamoli-Gopeshwar	Electro-coagulation	0.76	24.05.2022	Operational	Non-complying TSS, FC	Non-complying FC
7	Vivekanand Colony STP (Leesa Bend)	Chamoli-Gopeshwar	Electro-coagulation	1.19	10.06.2022	Operational	Non-complying FC	Non-complying FC
8	Pokhri Bend STP	Chamoli-Gopeshwar	Electro-coagulation	1.25	11.06.2022	Operational	Non-complying BOD, FC	Non-complying FC
9	Deen Dayal Uppadhyay Park	Chamoli-Gopeshwar	Electro-coagulation	1.12	10.06.2022	Operational	Non-complying FC	complying
10	Pokhri, Joshimath 1.08 MLD	Joshimath	SBR	1.08	09.06.2022	Operational	Complying -	complying -

S. No.	Name of STPs/CETPs	Ganga Front Town	Treatment Technology	Designed Capacity (MLD)	Date of Inspection	Operational /Non-Operational Status	Compliance Status w.r.t Hon'ble NGT norms dated 30.04.2019	Compliance Status w.r.t MoEF&CC norms dated 13.10.2017
11	Forest Nala STP	Nandprayag	Electro-coagulation	0.10	24.05.2022	Operational	Non-complying TSS, FC	Non-complying FC
12	Sangam Nala STP	Nandprayag	Electro-coagulation	0.05	24.05.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying FC
13	Near Police Chowki STP 01	Karanprayag	Electro-coagulation	0.05	24.5.2022	Operational	Non-complying FC	Non-complying FC
14	Old Bridge STP 02	Karanprayag	Electro-coagulation	0.1	25.5.2022	Operational	Non-complying BOD, COD, TSS & FC	Non-complying BOD, FC
15	Near Ward 1 & 3 STP 05	Karanprayag	Electro-coagulation	0.1	25.5.2022	Operational	Non-complying TSS, FC	Non-complying FC
16	BRO Bridge STP 04	Karanprayag	Electro-coagulation	0.05	25.5.2022	Operational	Non-complying TSS, FC	Non-complying FC
17	Subhash Nagar STP 03	Karanprayag	Electro-coagulation	0.05	24.5.2022	Operational	Non-complying TSS, FC	Non-complying FC
18	Near SBI Bank STP	Rudraprayag	Electro-coagulation	0.1	24.06.2022	Operational	Non-complying BOD, COD, TSS & FC	Non-complying FC
19	Near Dart Pull STP	Rudraprayag	Electro-coagulation	0.075	24.06.2022	Operational	Non-complying FC	Non-complying FC
20	Army Bend (Rudra Complex) STP 02	Rudraprayag	Electro-coagulation	0.1	24.06.2022	Operational	Non-complying TSS, FC	Non-complying FC
21	Anoop Negi Memorial School STP	Rudraprayag	Electro-coagulation	0.075	24.06.2022	Non-operational	-	-
22	Near Steel Bridge	Rudraprayag	Electro-coagulation.	0.125	24.06.2022	Operational	Non-complying FC	Non-complying FC
23	Baleni Road	Rudraprayag	Electro-coagulation	0.05	24.06.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying FC
24	Gyansu	Uttarkashi	MBBR	2	03.06.2022	Operational	Complying	Complying
25	Tekla STP	Uttarkashi	Biodigester	0.03	03.06.2022	Non-operational	-	-
26	Tehri	Tehri	ASP	5	25.05.2022	Operational	Non-complying COD, TSS, FC	Non-complying FC
27	0.075 MLD STP Junior High School, Srikot	Srikot	Fluidized Aerobic Bed	0.075	23.06.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying FC

S. No.	Name of STPs/CETPs	Ganga Front Town	Treatment Technology	Designed Capacity (MLD)	Date of Inspection	Operational /Non-Operational Status	Compliance Status w.r.t Hon'ble NGT norms dated 30.04.2019	Compliance Status w.r.t MoEF&CC norms dated 13.10.2017
28	0.05 MLD Taulia STP Srikot	Srikot	Fluidized Aerobic Bed	0.05	23.06.2022	Operational	Non-complying FC	Non-complying FC
29	Srinagar	Srinagar	Fluidized Aerobic Bed	3.5	23.06.2022	Operational	Non-complying BOD, COD TSS & FC	Non-complying FC
30	1.0 MLD STP, Near ITI, Srinagar,	Srinagar	SBR	1	23.06.2022	Operational	Complying	Complying
31	Kirtinagar	Kirti Nagar	Fluidized Aerobic Bed	0.05	23.06.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying BOD, FC
32	Kirtinagar	Kirti Nagar	Fluidized Aerobic Bed	0.01	23.06.2022	Operational	Non-complying COD, TSS, BOD & FC	Non-complying TSS, BOD, FC
33	Bah Bazar Devprayag	Devprayag	SBT (Soil Bio-technology)	1.4	31.05.2022	Operational	Non-complying TSS, BOD, COD & FC	Non-complying TSS, BOD, FC
34	Sangam Bazar Devprayag	Devprayag	SBR	0.15	31.05.2022	Operational	Non-complying COD, FC	Non-complying FC
35	Shanti Bazar Devprayag	Devprayag	SBR	0.075	31.05.2022	Operational	Non-complying TSS, COD, &FC	Non-complying FC
36	Tapovan	Tapovan	SBR	3.5	04.05.2022	Operational	Non-complying BOD, TSS, FC	Non-complying FC
37	Lakkarghat, Rishikesh	Rishikesh	SBR	26	26.05.2022	Operational	Complying	complying
38	Muni ki Reti	Muni ki Reti	MBBR	5	05.05.2022	Operational	Non-complying BOD, COD, FC	Non-complying FC
39	Chandreshwar STP	Muni ki Reti	MBBR	7.5	05.05.2022	Operational	Non-complying BOD, TSS, FC	Non-complying FC
40	Swarg Ashram Rishikesh	Rishikesh	SBR	3	26.05.2022	Operational	Non-complying COD, FC	Non-complying FC
41	Rishikesh, IDPL	Rishikesh	ASP	14	05.05.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying FC
42	Jagjeetpur, Haridwar (27 MLD)	Haridwar	SBR	27	09.05.2022	Operational	Non-complying FC	Non-complying FC
43	Jagjeetpur Haridwar (68 MLD)	Haridwar	SBR	68	09.05.2022	Operational	Non-complying FC	Non-complying FC
44	Jagjeetpur, Haridwar (18 MLD)	Haridwar	ASP	18	09.05.2022	Operational	Complying	complying

S. No.	Name of STPs/CETPs	Ganga Front Town	Treatment Technology	Designed Capacity (MLD)	Date of Inspection	Operational /Non-Operational Status	Compliance Status w.r.t Hon'ble NGT norms dated 30.04.2019	Compliance Status w.r.t MoEF&CC norms dated 13.10.2017
45	Sarai, Jawalapur STP (14 MLD)	Haridwar	SBR	14	11.05.2022	Operational	Non-complying COD, FC	Non-complying FC
46	Sarai, Jawalapur STP	Haridwar	SBR	18	11.05.2022	Operational	Complying	Complying
47	Old Mothrowala	Dehradun	SBR	20	01.08.2022	Operational	Non-complying FC	Non-complying FC
48	New Mothrowala	Dehradun	SBR	20	01.08.2022	Operational	Non-complying FC	Non-complying FC
49	Kargi	Dehradun	SBR	68	01.08.2022	Operational	Non-complying FC	Non-complying FC
50	Jakhan	Dehradun	SBR	1	02.08.2022	Operational	Non-complying COD, FC	Non-complying FC
51	Salawala	Dehradun	SBR	0.71	02.08.2022	Operational	Non-complying BOD, COD, TSS, FC	Non-complying FC
52	Vijay Colony	Dehradun	SBR	0.42	02.08.2022	Operational	Non-complying FC	Non-complying FC
53	Indira Nagar	Dehradun	SBR	5	02.08.2022	Operational	Non-complying FC	Non-complying FC

*General parameters of 1.0MLD Badrinath STP couldn't be analysed.

STPs complying to BOD Norms (<10mg/l) in Uttarakhand (July- Sept, 2022) w.r.t. NGT and MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	BOD (≤ 10 mg/l)
1	Chamoli Ghat	Chamoli-Gopeshwar	0.76	4
2	Vivekanand Colony STP (Leesa Bend)	Chamoli-Gopeshwar	1.19	7
3	Deen Dayal Uppadhyay Park	Chamoli-Gopeshwar	1.12	9
4	Pokhri, Joshimath 1.08 MLD	Joshimath	1.08	9
5	Forest Nala STP	Nandprayag	0.10	3
6	Near Police Chowki STP 01	Karanprayag	0.05	2
7	Near Ward 1 & 3 STP 05	Karanprayag	0.1	3
8	BRO Bridge STP 04	Karanprayag	0.05	8
9	Subhash Nagar STP 03	Karanprayag	0.05	6
10	Near Dart Pull STP	Rudraprayag	0.075	2
11	Army Bend (Rudra Complex) STP 02	Rudraprayag	0.1	7
12	Near Steel Bridge	Rudraprayag	0.125	4
13	Gyansu	Uttarkashi	2	7
14	Tehri	Tehri	5	8
15	0.05 MLD Taulia STP Srikot	Srikot	0.05	2

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	BOD (≤ 10 mg/l)
16	1.0 MLD STP, Near ITI, Srinagar,	Srinagar	1	6
17	Sangam Bazar Devprayag	Devprayag	0.15	7
18	Shanti Bazar Devprayag	Devprayag	0.075	8
19	Lakkarghat, Rishikesh	Rishikesh	26	5
20	Swarg Ashram Rishikesh	Rishikesh	3	9
21	Jagjeetpur, Haridwar (27 MLD)	Haridwar	27	10
22	Jagjeetpur Haridwar (68 MLD)	Haridwar	68	6
23	Jagjeetpur, Haridwar (18 MLD)	Haridwar	18	3
24	Sarai, Jawalapur STP (14 MLD)	Haridwar	14	10
25	Sarai, Jawalapur STP	Haridwar	18	7
26	Old Mothrowala	Dehradun	20	2
27	New Mothrowala	Dehradun	20	4
28	Kargi	Dehradun	68	2
29	Jakhan	Dehradun	1	7
30	Vijay Colony	Dehradun	0.42	2
31	Indira Nagar	Dehradun	5	4

• STPs complying to BOD Norms (11-30mg/l) in Uttarakhand (July- Sept, 2022) w.r.t. MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	BOD (11 mg/l to 30 mg/l)
1	Gangotri	Gangotri	1	11
2	Pokhri Bend STP	Chamoli-Gopeshwar	1.25	14
3	Sangam Nala STP	Nandprayag	0.05	12
4	Near SBI Bank STP	Rudraprayag	0.1	24
5	Baleni Road	Rudraprayag	0.05	15
6	0.075 MLD STP Junior High School, Srikot	Srikot	0.075	17
7	Srinagar	Srinagar	3.5	16
8	Tapovan	Tapovan	3.5	14
9	Muni ki Reti	Muni ki Reti	5	13
10	Chandreshwar STP	Muni ki Reti	7.5	11
11	Rishikesh, IDPL	Rishikesh	14	25
12	Salawala	Dehradun	0.71	12

• STPs non-complying to BOD Norms (≥ 30 mg/l) in Uttarakhand (July- Sept, 2022) w.r.t. NGT and MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	BOD (≥ 30 mg/l)
1	Badrinath 0.01MLD STP	Badrinath	0.01	1237

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	BOD (≥ 30 mg/l)
2	Badrinath 0.26 MLD STP	Badrinath	0.26	196
3	Old Suspension bridge	Chamoli-Gopeshwar	0.05	31
4	Old Bridge STP 02	Karanprayag	0.1	76
5	Kirti Nagar	Kirti Nagar	0.05	42
6	Kirtinagar	Kirti Nagar	0.01	100
7	Bah Bazar Devprayag	Devprayag	1.4	40

• STPs complying to COD (≤ 50 mg/l) in Uttarakhand (July- Sept, 2022) w.r.t. NGT Norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	COD (≤ 50 mg/l)
1	Chamoli Ghat	Chamoli-Gopeshwar	0.76	38
2	Vivekanand Colony STP (Leesa Bend)	Chamoli-Gopeshwar	1.19	44
3	Pokhri Bend STP	Chamoli-Gopeshwar	1.25	34
4	Deen Dayal Uppadhyay Park	Chamoli-Gopeshwar	1.12	40
5	Pokhri, Joshimath 1.08 MLD	Joshimath	1.08	48
6	Forest Nala STP	Nandprayag	0.10	16
7	Near Police Chowki STP 01	Karanprayag	0.05	9
8	Near Ward 1 & 3 STP 05	Karanprayag	0.1	12
9	BRO Bridge STP 04	Karanprayag	0.05	30
10	Subhash Nagar STP 03	Karanprayag	0.05	29
11	Near Dart Pull STP	Rudraprayag	0.075	13
12	Army Bend (Rudra Complex) STP 02	Rudraprayag	0.1	44
13	Near Steel Bridge	Rudraprayag	0.125	29
14	Gyansu	Uttarkashi	2	33
15	0.05 MLD Taulia STP Srikot	Srikot	0.05	8
16	1.0 MLD STP, Near ITI, Srinagar,	Srinagar	1	44
17	Tapovan	Tapovan	3.5	37
18	Lakkarghat, Rishikesh	Rishikesh	26	15
19	Chandreshwar STP	Muni ki Reti	7.5	44
20	Jageetpur, Haridwar (27 MLD)	Haridwar	27	29
21	Jageetpur Haridwar (68 MLD)	Haridwar	68	34
22	Jageetpur, Haridwar (18 MLD)	Haridwar	18	17
23	Sarai, Jawalapur STP	Haridwar	18	43
24	Old Mothrowala	Dehradun	20	15
25	New Mothrowala	Dehradun	20	15
26	Kargi	Dehradun	68	19
27	Vijay Colony	Dehradun	0.42	22
28	Indira Nagar	Dehradun	5	30

• STPs non-complying to COD (≥ 50 mg/l) in Uttarakhand (July- Sept, 2022) w.r.t. NGT norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	COD (≥ 50 mg/l)
1	Gangotri	Gangotri	1	71
2	Badrinath 0.01MLD STP	Badrinath	0.01	1803
3	Badrinath 0.26 MLD STP	Badrinath	0.26	451

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	COD (≥ 50 mg/l)
4	Old Suspension bridge	Chamoli-Gopeshwar	0.05	111
5	Sangam Nala STP	Nandprayag	0.05	59
6	Old Bridge STP 02	Karanprayag	0.1	167
7	Near SBI Bank STP	Rudraprayag	0.1	98
8	Baleni Road	Rudraprayag	0.05	55
9	Tehri	Tehri	5	60
10	0.075 MLD STP Junior High School	Srikot	0.075	61
11	Srinagar	Srinagar	3.5	52
12	Kirtinagar	Kirti Nagar	0.05	102
13	Kirtinagar	Kirti Nagar	0.01	281
14	Bah Bazar Devprayag	Devprayag	1.4	178
15	Sangam Bazar Devprayag	Devprayag	0.15	51
16	Shanti Bazar Devprayag	Devprayag	0.075	53
17	Muni ki Reti	Muni ki Reti	5	55
18	Swarg Ashram Rishikesh	Rishikesh	3	52
19	Rishikesh, IDPL	Rishikesh	14	98
20	Sarai, Jawalapur STP (14 MLD)	Haridwar	14	58
21	Jakhan	Dehradun	1	51
22	Salawala	Dehradun	0.71	67

• STPs complying to TSS (≤ 20 mg/l) in Uttarakhand (July- Sept, 2022) w.r.t. NGT and MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	TSS (≤ 20 mg/l)
1	Gangotri	Gangotri	1	18
2	Vivekanand Colony STP (Leesa Bend)	Chamoli-Gopeshwar	1.19	BDL
3	Pokhri Bend STP	Chamoli-Gopeshwar	1.25	BDL
4	Deen Dayal Uppadhyay Park	Chamoli-Gopeshwar	1.12	13
5	Pokhri, Joshimath 1.08 MLD	Joshimath	1.08	10
6	Near Police Chowki STP 01	Karanprayag	0.05	BDL
7	Subhash Nagar STP 03	Karanprayag	0.05	17
8	Near Dart Pull STP	Rudraprayag	0.075	11
9	Near Steel Bridge	Rudraprayag	0.125	20
10	Gyansu	Uttarkashi	2	12
11	0.05 MLD Taulia STP Srikot	Srikot	0.05	BDL
12	1.0 MLD STP, Near ITI, Srinagar,	Srinagar	1	18
13	Sangam Bazar Devprayag	Devprayag	0.15	11
14	Lakkarghat, Rishikesh	Rishikesh	26	BDL
15	Muni ki Reti	Muni ki Reti	5	15

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	TSS (≤ 20 mg/l)
16	Swarg Ashram Rishikesh	Rishikesh	3	12
17	Jagjeetpur, Haridwar (27 MLD)	Haridwar	27	BDL
18	Jagjeetpur Haridwar (68 MLD)	Haridwar	68	15
19	Jagjeetpur, Haridwar (18 MLD)	Haridwar	18	BDL
20	Sarai, Jawalapur STP (14 MLD)	Haridwar	14	16
21	Sarai, Jawalapur STP	Haridwar	18	BDL
22	Old Mothrowala	Dehradun	20	BDL
23	New Mothrowala	Dehradun	20	BDL
24	Kargi	Dehradun	68	BDL
25	Jakhan	Dehradun	1	BDL
26	Vijay Colony	Dehradun	0.42	7
27	Indira Nagar	Dehradun	5	BDL

• STPs complying to TSS (21 - 100 mg/l) in Uttarakhand (July- Sept, 2022) w.r.t. MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	TSS (21 - 100 mg/l)
1	Old Suspension bridge	Chamoli-Gopeshwar	0.05	46
2	Chamoli Ghat	Chamoli-Gopeshwar	0.76	55
3	Forest Nala STP	Nandprayag	0.10	56
4	Sangam Nala STP	Nandprayag	0.05	70
5	Old Bridge STP 02	Karanprayag	0.1	53
6	Near Ward 1 & 3 STP 05	Karanprayag	0.1	51
7	BRO Bridge STP 04	Karanprayag	0.05	26
8	Near SBI Bank STP	Rudraprayag	0.1	72
9	Army Bend (Rudra Complex) STP 02	Rudraprayag	0.1	21
10	Baleni Road	Rudraprayag	0.05	64
11	Tehri	Tehri	5	21
12	0.075 MLD STP Junior High School, Srikot	Srikot	0.075	54
13	Srinagar	Srinagar	3.5	46
14	Kirtinagar	Kirti Nagar	0.05	80
15	Shanti Bazar Devprayag	Devprayag	0.075	26
16	Tapovan	Tapovan	3.5	24
17	Chandreshwar STP	Muni ki Reti	7.5	23
18	Rishikesh, IDPL	Rishikesh	14	62
19	Salawala	Dehradun	0.71	25

- STPs non-complying to TSS (≥ 100 mg/l) in Uttarakhand (July- Sept, 2022) w.r.t. MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	TSS (≥ 100 mg/l)
1	Badrinath 0.01MLD STP	Badrinath	0.01	909
2	Badrinath 0.26 MLD STP	Badrinath	0.26	113
3	Kirtinagar	Kirti Nagar	0.01	203
4	Bah Bazar Devprayag	Devprayag	1.4	118

- STPs complying to FC (≤ 230 MPN/100 ml) in Uttarakhand (July- Sept, 2022) w.r.t. NGT and MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity	FC (≤ 230 MPN/100 ml)
1	Gangotri	Gangotri	1	<1.8
2	Pokhri, Joshimath 1.08 MLD	Joshimath	1.08	20
3	Gyansu	Uttarkashi	2	<1.8
4	1.0 MLD STP, Near ITI, Srinagar,	Srinagar	1	200
5	Lakkarghat, Rishikesh	Rishikesh	26	22
6	Jagjeetpur, Haridwar (18 MLD)	Haridwar	18	1.8
7	Sarai, Jawalapur STP	Haridwar	18	<1.8

- STPs complying to FC (230 - 1000 MPN/100 ml) in Uttarakhand (July- Sept, 2022) w.r.t. MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	FC (230 - 1000 MPN/100 ml)
1	Deen Dayal Upadhyay Park	Chamoli - Gopeshwar	1.12	470

- STPs non-complying to FC (≥ 1000 MPN/100 ml) in Uttarakhand (July- Sept, 2022) w.r.t. MoEF&CC norms

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	FC (≥ 1000 MPN/100 ml)
1	Badrinath 1.0 MLD STP	Badrinath	1	11×10^5
2	Badrinath 0.01MLD STP	Badrinath	0.01	27×10^{10}
3	Badrinath 0.26 MLD STP	Badrinath	0.26	17×10^6
4	Old Suspension bridge	Chamoli-Gopeshwar	0.05	22×10^5
5	Chamoli Ghat	Chamoli-Gopeshwar	0.76	22×10^4
6	Vivekanand Colony STP (Leesa Bend)	Chamoli-Gopeshwar	1.19	1100
7	Pokhri Bend STP	Chamoli-Gopeshwar	1.25	33000
8	Forest Nala STP	Nandprayag	0.10	7800
9	Sangam Nala STP	Nandprayag	0.05	110000
10	Near Police Chowki STP 01	Karanprayag	0.05	20×10^4
11	Old Bridge STP 02	Karanprayag	0.1	110000
12	Near Ward 1 & 3 STP 05	Karanprayag	0.1	68×10^4
13	BRO Bridge STP 04	Karanprayag	0.05	3300
14	Subhash Nagar STP 03	Karanprayag	0.05	7800
15	Near SBI Bank STP	Rudraprayag	0.1	23×10^7

S. No.	Name of STPs	Ganga Front Town	Designed Capacity (MLD)	FC (≥ 1000 MPN/100 ml)
16	Near Dart Pull STP	Rudraprayag	0.075	3300
17	Army Bend (Rudra Complex) STP 02	Rudraprayag	0.1	2200
18	Near Steel Bridge	Rudraprayag	0.125	17×10^3
19	Baleni Road	Rudraprayag	0.05	1400
20	Tehri	Tehri	5	22×10^5
21	0.075 MLD STP Junior High School	Srikot	0.075	39×10^3
22	0.05 MLD Taulia STP Srikot	Srikot	0.05	2000
23	Srinagar	Srinagar	3.5	13×10^5
24	Kirtinagar	Kirti Nagar	0.05	13×10^8
25	Kirtinagar	Kirti Nagar	0.01	39×10^7
26	Bah Bazar Devprayag	Devprayag	1.4	70×10^4
27	Sangam Bazar Devprayag	Devprayag	0.15	11×10^4
28	Shanti Bazar Devprayag	Devprayag	0.075	78000
29	Tapovan	Tapovan	3.5	54×10^7
30	Muni ki Reti	Muni ki Reti	5	27×10^3
31	Chandreshwar STP	Muni ki Reti	7.5	34000
32	Swarg Ashram Rishikesh	Rishikesh	3	21×10^5
33	Rishikesh, IDPL	Rishikesh	14	23×10^4
34	Jagjeetpur, Haridwar (27 MLD)	Haridwar	27	31000
35	Jagjeetpur Haridwar (68 MLD)	Haridwar	68	2000
36	Sarai, Jawalapur STP (14 MLD)	Haridwar	14	33000
37	Old Mothrowala	Dehradun	20	2000
38	New Mothrowala	Dehradun	20	39000
39	Kargi	Dehradun	68	48000
40	Jakhan	Dehradun	1	49×10^4
41	Salawala	Dehradun	0.71	70×10^4
42	Vijay Colony	Dehradun	0.42	21×10^4
43	Indira Nagar	Dehradun	5	24×10^4

NGT Standards: Compliance based on norms prescribed by Hon'ble NGT vide order dt 30.04.2019 in the matter of OA no. 1069/2018 (pH – 5.5-9.0, BOD <10mg/l, TSS < 20mg/l, COD < 50mg/l; Faecal Coliform – desirable <100MPN/100ml & permissible < 230 MPN/100 ml, Nitrogen-Total < 10 mg/l and Phosphorous-Total < 1.0 mg/l (TP compliance for discharge into ponds and lakes).

Compliance compared with MoEF&CC notification dt. 13.10.2017: Standard for treated sewage from STPs for cities other than metro cities, state capitals and union territories were notified as pH-6.5-9.0, BOD as 30mg/L, Total suspended solids (TSS) as less than 100mg/L and Faecal coliform as less than 1000MPN per 100mL.